



Product Service

# Attestation of Conformity

No. N8A 113676 0014 Rev. 01

**Holder of Certificate:** **Guangdong Carrier Heating, Ventilation & Air Conditioning Company Limited**

No.1, Helangsha, Shengli Village, Lishui Town  
Nanhai District  
528244 Foshan, Guangdong Province  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Heat pumps**  
**(Air-To-Water Split Type Heat Pump)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64111200117403

**Date,** 2022-07-18

( Sam Yang )

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

# Attestation of Conformity

No. N8A 113676 0014 Rev. 01

**Model(s):** Indoor unit/Outdoor unit:  
CLP-V8HN/DR4/CLP-V5HW/DR4,  
CLP-V8HN/DR4/CLP-V8HW/DR4,  
CLP-V12HN/DR4/CLP-V10HW/DR4,  
CLP-V12HN/DR4/CLP-V12HW/DR4.

**Brand:** GCHV

**Parameters:**

Rated Voltage:	220-240V~
Rated Frequency:	50Hz
Rated Power/Current:	CLP-V8HN/DR4: 3600W/17A CLP-V5HW/DR4: 2860W/13A CLP-V8HW/DR4: 4200W/19A CLP-V12HN/DR4: 3600W/17A CLP-V10HW/DR4: 5000W/22A CLP-V12HW/DR4: 5000W/22A
Protection Class:	Class I
Degree of Protection:	IPX4 for outdoor unit, IPX1 for indoor unit
Refrigerant:	R32

**Tested according to:** EN 60335-1:2012/A15:2021  
EN 60335-2-40:2003/A13:2012  
EN 62233:2008