

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CL0333

Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Distributor</b> <i>Vertreiber</i>	Türk Demirdöküm Fab. A.S. Bozüyük Tesi. 4 Eylül Mah., No: 245, TR-11300 Bozüyük - Bilecik
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
<b>Product Description</b> <i>Produktbezeichnung</i>	condensing boiler
<b>Model</b> <i>Modell</i>	MAXI CONDENSE 128
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AT, BE, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: B 18/02/2594 EU from 16.03.2018 (DBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15417 (01.11.2006) DIN EN 13836 (01.06.2007)

**Validity / File no.** 21.04.2018 until 11.04.2028 / 18-0269-GEA  
**Gültigkeit / AZ**

70028-04-A-DE

11.04.2018 Kö D-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.




DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

**Elektrical Data**                    230 V AC, 50 Hz  
*Elektrische Daten*

<b>Appliance Categories</b> <i>Gerätekatgorien</i>	<b>Supply Pressures</b> <i>Versorgungsdrücke</i>	<b>Countries of Destination</b> <i>Bestimmungsländer</i>	<b>Remarks</b> <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I3+	28-30/37 mbar	BE	
I3B/P	30 mbar	CY, IS, MT	
I12E+3+	20/25, 28-30/37 mbar	FR	
I12E3B/P	20, 37 mbar	PL	
I12E3P	20, 37 mbar	LU	
I12ELL3B/P	20, 50 mbar	DE	
I12Esi3+	20/25, 28-30/37 mbar	FR	
I12Esi3B/P	20/25, 28-30 mbar	FR	
I12H3+	18, 28-30/37 mbar	ES	
I12H3+	20, 28-30/37 mbar	GB, GR, IE, SI, SK	
I12H3+	20, 30/37 mbar	IT, PT	
I12H3B/P	20, 28-30 mbar	HR	
I12H3B/P	20, 30 mbar	DK, EE, FI, IE, LT, LV, NO, RO, SE, SI, SK, TR	
I12H3B/P	20, 50 mbar	AT, CH, CZ, LU, SK	
I12H3B/P	25, 30 mbar	HU	
I12H3P	20, 37 mbar	SI, SK	
I12L3B/P	25, 30 mbar	NL	

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
MAXI CONDENSE 128	nominal heat output: 113,4 kW nominal heat input (Hi): 115,0 kW	

#### **Hints of Utilization /Remarks**

##### **Verwendungshinweise / Bemerkungen**

Electrical data: 230 V AC, 50 Hz

additional countries of destination/ appliance categories: TK: I12H3B/P: 20 mbar, 30 mbar

flue types: B23, B53, B53P, C13, C33, C53, C63 according to installation manual with PP-flue system T120 H1 W2 of Centrotec (0036 CPD 9169 003)

DVG